



AZIZ PUBLIC SCHOOL

CBSE Affiliation No. 3330509, School Code- 16239

Near IB Group Corporate office, Rajnandgaon (C.G.), Pin- 491441, Mobile- 7880094386, E-mail- aps_indamara@ibgroup.co.

Ref. no. APSI / 536

Date:

Date: - 27/02/2025

To,

C.E.O.

JILA PANCHAYAT

Rajnandgaon (C.G.)

Subject- Request to provide certificate for health and Sanitary conditions.

Dear Sir,

This is to bring to your notice that Aziz Public school Indamara needs health and sanitation certificate needed every year as per CBSE bylaws. Previous certificate given by your good office is going to expire soon.

So kindly request you to provide the certificate as soon as possible.

Sincere Regards

Principal

Aziz Public School
Indamara, RAJNANDGAON (C.G.)



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1437

Dated: 13.03.2025

It is certified that an inspection team headed by Mr. Rajesh Mishra, I/C Health Officer
(Name of Officers with designation) from Municipal Corporation

inspected the **AZIZ PUBLIC SCHOOL, INDAMARA, RAJNANDGAON,**

on **12.03.2025** (date of inspection) and on the basis of Water Test Report bearing
no. DL/PHED/RJN/452 dated **05.03.2025** of (PHED Lab) certified that the

AZIZ PUBLIC SCHOOL, INDAMARA has safe drinking water facilities for the students
and members of staff of the institution. School also maintains the hygienic sanitation
condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid for a period of Two years.

Signature with Seal: _____


Health Officer

Municipal Corporation

Name: RAJESH MISHRA Rajnandgaon (C.G.)

Designation: I/C HEALTH OFFICER

To

THE PRINCIPAL

AZIZ PUBLIC SCHOOL,

INDAMARA, RAJNANDGAON (C.G.)

Principal
AZIZ PUBLIC SCHOOL
INDAMARA, RAJNANDGAON (C.G.)

जिला जल परीक्षण प्रयोगशाला
लोक स्वास्थ्य यांत्रिकीय खण्ड, राजनांदगाँव (छ.ग.)

क्रमांक / 219 / स.अ. / प्र.शा. / लो.स्वा.यां.खण्ड / 2025

राजनांदगाँव, दिनांक 12/03/25

प्रति,

PRINCIPAL,
Aziz Public School, Indamara
Rajnandgaon (C.G.)


विषय :- जल परीक्षण पत्रक।

संदर्भ :- आपका पत्र क्र 541 दिनांक 03.03.2025

—000—

उपरोक्त विषयान्तर्गत लेख है आपके माध्यम से कुल 01 जल नमूना परीक्षण हेतु प्राप्त हुआ, जिसका परीक्षण पत्रक आवश्यक कार्यवाही हेतु प्रेषित है।

सहपत्र :- 1. 03 नग परीक्षण पत्रक।
2. देयक पत्रक।


सहायक अभियंता,
लोक,स्वा.यांत्रिकी उपखण्ड
राजनांदगाँव (छ.ग.)



TC-6693

District Water Testing Laboratory

Public Health Engineering Department, Division-Rajnandgaon (C.G.)

e-mail - phelabraj@gmail.com, Phone No. - 07744 - 224035

Test Report - Chemical

ULR - TC669325000000747F

Report No. - RJN/747/07-03-25

Smpled by:- PRINCIPAL, Aziz Public School Indamara
Rajnandgaon (C.G.)

Sample Code :-	747	Sampled On :-	06.03.2025
Sample Name :-	Drinking Water	Quantity of Sample :-	1 Ltr/Sample
Sender's letter No. -	541	Sender's Letter Date :-	03.03.2025
Sample Condition :-	Good	Sample Received On :-	06.03.2025
Test Started on:-	06.03.2025	Test Completed On :-	07.03.2025

Sample Details

S.No.	Block	Sample I.D.	Village	Location	Source Discription
1	Rajnandgaon	747/6326/Mar/25	Indamara	Aziz Public School Indamara Rajnandgaon (C.G.)	-

Details of parameters, their test methods, units and specifications as per IS:3025 /APHA

S.No.	Characteristics	Unit of Measurement	Test method IS 3025 / APHA 24th edition		Acceptable Limit	Permissible Limit in the absence of alternate source	Result of
			Method	Part No.			
1	Turbidity	N.T.U.	IS:3025	10	1	5	1.0
2	Colour	Hazen	APHA	2120- B	5	15	5
3	Odour	IS:3025	5	Agreeable	Agreeable	Agreeable
4	Taste	IS:3025	8	Agreeable	Agreeable	Agreeable
5	pH value	IS:3025	11	6.5-8.5	No Relaxation	8.00
6	Total Alkalinity as CaCO ₃	mg/l	IS:3025	23	200	600	34.7
7	Spe. Conductivity @25°C	µmho/cm	IS:3025	14	-	-	125
8	Total Dissolved Solids At 180°C ± 2°C	mg/l	IS:3025	16	500	2000	90
9	Chloride as Cl ⁻	mg/l	APHA	4500 - Cl-B	250	1000	12.06
10	Total Hardness as CaCO ₃	mg/l	IS:3025	21	200	600	57.1



TC-6693

District Water Testing Laboratory

Public Health Engineering Department, Division-Rajnandgaon (C.G.)

e-mail - phelabraj@gmail.com, Phone No. - 07744 - 224035

Test Report - Chemical

ULR - TC669325000000747F

Details of parameters, their test methods, units and specifications as per IS:3025 /APHA

S.No.	Characteristics	Unit of Measurement	Test method IS 3025 / APHA 24th edition		Acceptable Limit	Permissible Limit in the absence of alternate source	Result of
			Method	Part No.			
11	Calcium (As Ca^{2+})	mg/l	IS:3025	40	75	200	15.7
12	Magnesium (As Mg^{2+})	mg/l	APHA	3500 - Mg-B	30	100	4.3
13	Nitrates as NO_3^- (Screening Method)	mg/l	APHA	4500- NO_3^- -B	45	No Relaxation	2.6
14	Iron as Fe^{2+}	mg/l	APHA	3500-Fe-B	1.0	No Relaxation	0.10
15	Manganese (As Mn^{+})	mg/l	APHA	3500-Mn-B	0.1	0.3	Nil
16	Sulphates as SO_4^{2-}	mg/l	IS:3025	24	200	400	7.05
17	Fluorides as F^-	mg/l	APHA	4500-F-C	1.0	1.5	Nil
18	Arsenic as As	mg/l	IS:3025	37	0.01	No Relaxation	Nil

Terms & Condition :-

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. Results apply to the sample as received.
5. Sampling not done by Laboratory's Staff.
6. The Laboratory does not give interpretation on test result passed/failed.

(Signature)
Chemist
(Purnima Mishra)
Authorized Signatory

END OF THE REPORT

District Water Testing Laboratory

Public Health Engineering Department, Division-Rajnandgaon (C.G.)

e-mail - phelabraj@gmail.com, Phone No. - 07744 - 224035

Test Report – Chemical / Bacterial

Report No. - RJN/747/07-03-25		Sampled by:- PRINCIPAL, Aziz Public School Indamara Rajnandgaon (C.G.)	
Sample Code :-	747	Sampled On :-	06.03.2025
Sample Name :-	Drinking Water	Quantity of Sample :-	1 Ltr/Sample
Sender's letter No. -	541	Sender's Letter Date :-	03.03.2025
Sample Condition :-	Good	Sample Received On :-	06.03.2025
Test Started on:-	06.03.2025	Test Completed On :-	07.03.2025

Sample Details


S.No.	Block	Sample I.D.	Village	Location	Source Discription
1	Rajnandgaon	747/6326Mar/25	Indamara	Aziz Public School Indamara Rajnandgaon (C.G.)	-

Details of parameters, their test methods, units and specifications as per IS:3025 /APHA

S.No.	Characteristics	Unit of Measurement	Test method IS 3025 / APHA 24th edition		Acceptable Limit	Permissible Limit in the absence of alternate source	Result of
			Method	Part No.			
1	Residual chlorine	mg/l	IS:3025	26	0.2	1	Nil
2	E.coli	CFU/100	IS:15185	-	Nil	Nil	Nil
3	Coliform	CFU/100	IS:15185	-	Nil	Nil	-

Terms &Condition :-

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. Results apply to the sample as received.
5. Sampling not done by Laboratory's Staff.
6. The Laboratory does not give interpretation on test result passed/failed.


Chemist
(Purnima Mishra)
Authorized Signatory

END OF THE REPORT